



Addendum #1
Granite Creek Water Main Repair
2/24/25

1. Can the District please provide clarification regarding the “pavement restoration” in the project description:
 - Pavement restoration includes the removal and replacement of AC paving with respect to the pipe replacement trench T-cut as well as additional pavement restoration outside the limits of the typical T-cut per the City of Scotts Valley field designations. Per the plans: Note: Final limits of pavement restoration is to be determined after the line and grade survey.
2. Have the line and grade survey been completed, if so, what is the square footage?
 - Line and grade survey are to be done by the Contractor and submitted to the Engineer for review.
3. Did the bid documents reflect a bid space for paving restoration or is this to be integrated with the 8” C900 line item?
 - Bid Item #8 was added to account for the AC pavement restoration outside the typical trench T-cut which is included in Bid Item #4. Please see attached for the Revised Bid Form I-C (Page 9 of Section I). Most of this work will be at the southwest curb return of Granite Creek Road and Sherman Drive (The engineering estimate is 28 SY but include a minimum of 40 SY in the bid tab for any overage).

Here's the Bid Item #8 description:

Additional AC Paving and Restoration:

- a. *The unit bid price per square yard shall constitute full compensation for all material, labor, equipment, tools, and services necessary to provide additional asphalt concrete paving, 6-inches thick with 16-inches of aggregate base outside the limits of the T-cut for trench restoration.*
 - b. *Measurement shall be in-place limits of the additional pavement (length x width).*
 - c. *This Bid Item establishes a unit rate for additional AC paving outside the typical T-cut for trench restoration and unforeseen work.*
- Bid Item #4 includes backfill and pavement restoration for all pipe replacement work. Bid Item #8 has been added to account for additional AC paving outside the limits of the typical T-cut.

1-C BID FORM

SCOTTS VALLEY WATER DISTRICT

GRANITE CREEK WATERMAIN REPLACEMENT

Contractor: _____

Business Address: _____

Phone: _____ Email: _____

Contractor License: _____ Class: _____ Expiration Date: _____

DIR Registration _____

Pursuant to the Notice Inviting Bids, and in compliance with the Instructions to Bidders, having obtained and reviewed the Contract Documents and the project site, the undersigned hereby proposes to furnish all work, labor, materials, transportation, equipment, and services necessary, including State of California and local sales or use taxes, license, and permit fees, for the Scotts Valley Water District Granite Creek Watermain Replacement, all in accordance with the Contract Documents together with addenda issued prior to or at the time of bidding, if any, now on file with the District Representative, for the sum of

Item No.	Description	Unit	Estimated Quantity	Bid Unit Price	Bid Price
1	Mobilization/Demobilization	LS	1	\$	\$
2	Sheeting, Shoring and Bracing	LS	1	\$	\$
3	Traffic Control	LS	1	\$	\$
4	8-inch C900 PVC Water Main	LF	220	\$	\$
5	1-inch Residential Water Service	EA	3	\$	\$
6	Concrete Curb and Gutter	LF	220	\$	\$
7	Concrete Sidewalk	SF	800	\$	\$
8	Additional AC Paving	SY	50		
Total Bid Price in Numbers:				\$	

Total bid price in Words:

_____ Dollars

All bid entries must be filled in.

Addenda Received and Reviewed: