



#### NOTES

1. HYDRANT SHALL BE 6" "STEAMER" TYPE; CLOW MODEL 860, OR APPROVED EQUAL.
2. REMOVE HYDRANT OUTLET CAP CHAINS PERMANENTLY.
3. HYDRANT SHALL BE COVERED WITH BURLAP SACK OR APPROVED ORANGE BAG WHEN NOT IN SERVICE.
4. FIRE HYDRANT LOCATION SHALL BE APPROVED ON A CASE BY CASE BASIS PRIOR TO CONSTRUCTION AND SHALL INCLUDE FIRE AGENCY APPROVED PLANS, CITY OR COUNTY ENCROACHMENT PERMIT, AND FIELD VERIFICATION BY THE APPROPRIATE FIRE AGENCY, CITY OR COUNTY PUBLIC WORKS DEPARTMENT AND SVWD, PER SVWD HYDRANT INSTALLATION PERMIT REQUIREMENTS PRIOR TO CONSTRUCTION.
5. SEE APPENDIX 1 FOR FURTHER HYDRANT INSTALLATION REQUIREMENTS.



SCOTTS VALLEY WATER DISTRICT  
WWW.SVWD.ORG

### DETAIL 10

FIRE HYDRANT INSTALLATION

NOT TO SCALE