



NOTES

1. RISER TERMINATION FOR GATE VALVE INSTALLATION SHALL OCCUR AT VALVE FLANGE (SEE DETAIL 11).
2. RISER TERMINATION FOR SERVICE CONNECTION (2" & SMALLER) SHALL OCCUR 1" BELOW CORP STOP.
3. VALVE BOX LID SHALL BE OILED PRIOR TO PAVING OR CLEANING TO ENSURE THAT LID MARKINGS ARE LEGIBLE.
4. INSTALL VALVE BOX LID FLUSH WITH FINAL PAVING OR GROUND SURFACE.



SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

DETAIL 13

VALVE BOX INSTALLATION

NOT TO SCALE