



STANDARD SERVICE LATERAL TRENCH

NOTES

1. IF ANY PORTION OF (E) PAVEMENT WITHIN SAWCUT LIMITS IS CONCRETE AT THE SURFACE, ENTIRE TRENCH SHALL BE RE-PAVED WITH CONCRETE AS SHOWN.
2. WHERE WATER SERVICES 6" AND LARGER CANNOT MEET MINIMUM COVER REQUIREMENTS, THE ENGINEER MAY APPROVE ALTERNATE INSTALLATION PER DETAIL 16.
3. ALL JOINTS ON SERVICE LATERALS SHALL BE RESTRAINED.



SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

DETAIL 14

STANDARD SERVICE LATERAL TRENCH

NOT TO SCALE