



WATER MAIN TRENCH

FOR MAINS INSTALLED AT SUB-STANDARD DEPTH

NOTES

1. USE OF THIS DETAIL REQUIRES PRIOR APPROVAL OF THE ENGINEER. REFER TO DETAIL 15 FOR STANDARD TRENCH
2. IF ANY PORTION OF (E) PAVEMENT WITHIN SAWCUT LIMITS IS CONCRETE AT THE SURFACE, ENTIRE TRENCH SHALL BE RE-PAVED WITH CONCRETE AS SHOWN,
3. REFER TO SVWD TECHNICAL SPECIFICATIONS FOR COMPACTION TESTING REQUIREMENTS.
4. FOR SERVICE LATERALS REFER TO DETAIL 14.



SCOTTS VALLEY WATER DISTRICT
WWW.SVWD.ORG

DETAIL 16

SUB-STANDARD WATER MAIN TRENCH

NOT TO SCALE