



NOTES

1. CONTRACTOR SHALL VERIFY (E) MAIN DIAMETER PRIOR TO SCHEDULING SYSTEM SHUT DOWN.
2. ELBOWS SHARPER THAN 45° ARE NOT ALLOWED.
3. PIPE AND FITTING SIZES & MATERIAL SHALL BE SPECIFIED BY ENGINEER.
4. JOINT RESTRAINTS AND THRUST BLOCKING PER DETAILS 19 AND 20 ARE REQUIRED.
5. TEMPORARY THRUST BLOCKING MAY BE REQUIRED WHILE CONCRETE CURES.



SCOTTS VALLEY WATER DISTRICT
WWW.SVWD.ORG

DETAIL 17

SYSTEM CONNECTION (TIE IN)

NOT TO SCALE