



NOTES

1. BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
2. CHLORINATION TAPS SHALL NOT BE LOCATED FURTHER THAN 10 FEET DOWNSTREAM OF THE BEGINNING OF THE NEW MAIN.
3. BOX SHALL BE LOCATED AS INDICATED BY CONTRACT DOCUMENTS OR THE ENGINEER.
4. AFTER DISINFECTION, CLOSE AND CAP CORPORATION STOP AND REMOVE ALL COMPONENTS.



SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

DETAIL 22

CHLORINATION TAP INSTALLATION

NOT TO SCALE