



#### NOTES

1. EXACT LOCATIONS OF TAP AND OF AIR VALVE SHALL BE APPROVED BY THE ENGINEER PRIOR TO INSTALLATION.
2. BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
3. AT THE DISCRETION OF THE ENGINEER, A GATE VALVE AND BOX SHALL BE INSTALLED NEAR THE CONNECTION AT THE MAIN PER DETAIL 11.
4. INSTALL LOCKING STEEL ENCLOSURE AND CONCRETE PAD IF REQUIRED BY THE ENGINEER.
5. ABOVE GROUND PIPING, FITTINGS AND ENCLOSURE SHALL BE PAINTED W/ TWO COATS OF RUST PREVENTATIVE ENAMEL.
6. INSTALL TRAFFIC BOLLARD(S) PER DETAIL 20 WHERE REQUIRED BY THE ENGINEER.



SCOTTS VALLEY WATER DISTRICT  
WWW.SVWD.ORG

**DETAIL 24**

ABOVE GRADE AIR VALVE INSTALLATION

NOT TO SCALE