

- BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
- FIRE SERVICES SHALL NOT BE COMBINED WITH OTHER SERVICES IN THIS MANNER.
- 3. PERMISSION TO INSTALL SERVICES IN OTHER CONFIGURATIONS NOT SHOWN HERE MAY BE GRANTED BY THE ENGINEER. IN THIS CASE, THE DEVELOPER SHALL SUBMIT CALCULATIONS WHICH DEMONSTRATE TO THE SATISFACTION OF THE ENGINEER THAT THE RESIDUAL PRESSURE IS GREATER THAN A SINGLE SERVICE WHEN ALL SERVICES ARE FULLY OPEN.



SCOTTS VALLEY WATER DISTRICT WWW.SVWD.ORG

DETAIL 3

1-INCH AND SMALLER MULTIPLE BRANCHED SERVICE INSTALLATION

NOT TO SCALE