

- LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI. FIRE SERVICE LINE SHALL BE TESTED FOR LEAKS PRIOR
- TO BACKFILLING.
- CUSTOMER SIDE FIRE SERVICE PIPE TYPE AND CONNECTION SHALL MEET LOCAL FIRE AGENCY REQUIREMENTS.
- 4. PURCHASE LIDS FROM SVWD



DETAIL 4

COMBINATION 2-INCH FIRE AND DOMESTIC SERVICE INSTALLATION

NOT TO SCALE