



METER SIZE AND TYPE (ASSIGNED BY SVWD)	BOX TYPE (SEE DETAIL 2)	METER LENGTH, a
5/8" THREADED	"16"	7 3/4"
3/4" THREADED	"16"	7 3/4"
1" THREADED	"16"	11"
1 1/2" FLANGED	"36"	13"
2" FLANGED	"36"	15 1/4"

NOTES

- BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
- METER WILL BE FURNISHED AND INSTALLED BY DISTRICT
- A BACKFLOW PREVENTION ASSEMBLY SHALL BE INSTALLED PER DETAIL 8 IF REQUIRED BY THE ENGINEER.



SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

DETAIL 5

2-INCH AND SMALLER SERVICE
INSTALLATION

NOT TO SCALE