


#### NOTES

1. APPROVED BACKFLOW ASSEMBLY SHALL BE INSTALLED SUCH THAT IT IS ABOVE GROUND AND READILY ACCESSIBLE FOR REPAIR AND INSPECTION.
2. BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
3. BRASS OR PLASTIC PLUGS SHALL BE INSTALLED ON ALL TEST PORTS.
4. ALL ABOVE GROUND PIPE, FITTINGS AND ASSEMBLY SHOULD BE PAINTED WITH TWO COATS OF ENAMEL.
5. AN ENCLOSURE OR CAGE MAY BE INSTALLED AT THE OPTION OF THE PROPERTY OWNER.



SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

**DETAIL 8**

2-INCH AND SMALLER BACKFLOW PREVENTION ASSEMBLY INSTALLATION

NOT TO SCALE