



NOTES

1. APPROVED BACKFLOW ASSEMBLY SHALL BE INCLUDED IN THE CURRENT "LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES," FOUNDATION FOR CROSS-CONNECTION AND HYDRAULIC RESEARCH, USC, SCHOOL OF ENGINEERING. APPROVED ASSEMBLY SHALL BE INSTALLED SUCH THAT IT IS READILY ACCESSIBLE FOR REPAIR AND INSPECTION.
2. BRASS FITTINGS, VALVES AND PIPE SHALL CONSIST OF LOW-LEAD BRASS ALLOY AND SHALL HAVE A MINIMUM WORKING PRESSURE OF 150 PSI.
3. BRASS OR PLASTIC PLUGS SHALL BE INSTALLED ON ALL TEST PORTS.
5. ALL FITTINGS BETWEEN DISTRICT METER AND BACKFLOW DEVICE SHALL BE NSF 61 CERTIFIED MATERIAL.
6. ALL ABOVE GROUND PIPE, FITTINGS AND ASSEMBLY SHOULD BE PAINTED WITH TWO COATS OF ENAMEL.
7. AN ENCLOSURE OR CAGE MAY BE INSTALLED AT THE OPTION OF THE PROPERTY OWNER.



SCOTTS VALLEY WATER DISTRICT

SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

DETAIL 8

2-IN & SMALLER BACKFLOW PREVENTION ASSEMBLY INSTALLATION

NOT TO SCALE