



ELEVATION VIEW

NOTES

1. APPROVED BACKFLOW ASSEMBLY SHALL BE INCLUDED IN THE CURRENT "LIST OF APPROVED BACKFLOW PREVENTION ASSEMBLIES," FOUNDATION FOR CROSS-CONNECTION AND HYDRAULIC RESEARCH, USC, SCHOOL OF ENGINEERING. APPROVED ASSEMBLY SHALL BE INSTALLED SUCH THAT IT IS READILY ACCESSIBLE FOR REPAIR AND INSPECTION.
2. LOCATIONS MUST BE APPROVED BY SVWD PRIOR TO INSTALLATION
3. PAINT ALL EXPOSED PIPE, FITTINGS AND ASSEMBLY WITH 2-COATS OF RED COLORED RUST PREVENTATIVE ENAMEL.



SCOTTS VALLEY WATER DISTRICT

SCOTTS VALLEY WATER DISTRICT

WWW.SVWD.ORG

DETAIL 9A

VERTICAL 2-INCH FIRE AND SMALLER FIRE SERVICE BFD INSTALLATION

NOT TO SCALE